



Advanced Composite Technology

50 Pine Road, Brentwood, NH 03833

Phone: 603/778-8899

Fax: 603/778-7455

e-mail: nei@nei-act.com

Dave Hagar  
c/o Boral Roofing  
7575 Irvine Center Drive, Suite 100  
Irvine, CA 92618

Dear Mr. Hagar,

NEI requires that all Oriented Strand Board (OSB) must be primed with an asphalt based primer before application of any of our self-adhered underlayments/membranes when applied directly to the roof deck. Mechanically fastened base sheets or underlayments do not require priming of the OSB. Please let me know if you have any further questions. Thank you.

Sincerely,

A handwritten signature in dark ink, appearing to read "Elizabeth Butler", with a long, sweeping underline.

Elizabeth Butler  
Sales & Marketing Manager  
Northern Elastomeric Inc.